1(3) DATA SHEET

G000267



# I/O M 70 H

Part no. 5100075-01A

System: TERRA FIRE

### General Description

I/O M 70 provides eight programmable I/O 70 channels, each individual channel can be configured as either:

- Programmable Inputs
- Programmable Outputs max 70mA for buzzers, relays etc
- Conventional detector zones

This module monitors conventional detectors, digital inputs, two-wired inductive sensors and controls low-power units, such as buzzers and relays.

For details on assembling a system and definitions of common system terms, refer to the Installation Manual.

#### Data

Operating voltage range 19-30 VDC Current consumption 12 mA

(at 24 V)

Current consumption (at 32 mA

8 EIR 10 kΩ)

 $\begin{array}{lll} \text{Max, current per channel} & 70 \text{ mA} \\ \text{Max, total current} & 0.6 \text{ A} \\ \text{ELR fire zones} & 10 \text{ k}\Omega \\ \text{ELR input} & 10 \text{ k}\Omega \\ \text{Cable terminals} & 2.5 \text{ mm}^2 \end{array}$ 

Operating temperature

arige

-5°C to +55°C

Weight (with housing)

130g

Spare part no.

5100074-03A

(without housing)

Certified according to


**C €**<sub>09</sub> 2531-CPR-232.1686 DOP no. 6301900

#### Settings

The module is identified by a physical address on the Backbone Bus. The address is set with an 8-pole DIP switch.

#### Address switch

The DIP switch value follows the binary system. The address no. can be set from 1 to 126 using DIP-switch poles 1 to 7.



G000668

#### Connections



G000168

The specifications described herein are subject to change without notice.

Data sheet no. 5100075-01A\_I-O M 70 H\_I0\_EN\_2015\_G




DATA SHEET 2(3)

I/O M 70 ADDRESS:														
1 2			3		4		5		6		7		8	
PROGRAMMABLE OUTPUT	PROGRAMMABLE OUTPUT	1/0 70												
24V 70mA	4V 24V 70mA		24V 70mA											
7 7	2+	2-	3+	φ	4+	4	5+	Ş-	6+	6	7+	7-	8+	8-

G002246

### **Indicators**



G000748


Indicator	Colour, pattern	Module status when used as an input	Module status when used as an output		
	Red	The input is activated	The output is ON		
Channels 1 – 8	Yellow	Input fault	Output fault		
	None	The input is not activated	The output is OFF		


Indicator	Colour, pattern	Module status		
DC (D C 1 )	Green	Power OK		
PS (Power Supply)	Yellow	Power Fault		
	Green	Communication OK		
COM (Communication)	Green, flashing	Communication OK, module not configured		
	Yellow	Communication fault		
PS + COM	PS = Yellow, flashing COM = Green	Boot-loader mode		
PS + COM (both flashing)	PS = Yellow, flashing COM = Yellow, flashing	Boot-loader mode, Firmware download in progress		
PS + COM	PS = Yellow, flashing COM = None	Safe State (module is not functional)		



3(3) DATA SHEET

# Module Dimensions (mm)





G001036

## Mounting

Mount the module on a horizontal 35 mm DIN rail.

**© Consilium** 

Building Safety